



CITY OF ANTIGO

PUBLIC WORKS COMMITTEE MEETING

MULTI-PURPOSE ROOM

Wednesday, June 27, 2018

CITY HALL, 700 EDISON STREET

5:30 PM

Call to Order

Discussion and Action May Occur on Any of the Following Agenda Items:

1. Approval of the Minutes from the May 23, 2018 Meeting
2. Approval of Purchase of Influent Pump for Wastewater Treatment Plant and Waiver of Bidding Process

Any Other Matters Authorized by Law to be Considered

Adjournment

Upon reasonable notice, efforts will be made to accommodate disabled individuals through appropriate aids and services. For additional information, contact Jaime Horswill, 700 Edison Street, Antigo, Wisconsin 54409. (715) 623-3633 extension 100. Members of and possibly a quorum of members of other governmental bodies may be in attendance to gather information. Any governmental body other than that specifically referred to above will take no action.

DATE MAILED: June 19, 2018

TOM BAUKNECHT



Headquarters
707 Ford Street, Kimberly, WI 54136
 t. 920-733-4425 f. 920-733-0211

R.D. Smith, A Crane Company
 2703 Bauer St, Eau Claire, WI 54701
 t. 715-832-3479

QUOTE

Number CESQ4847
Date Jun 12, 2018
Expires Jul 12, 2018

Sold To

Infrastructure Alternatives, Inc.
 Tommy Horswill
 Antigo WWTP
 N2420 Koszarek Rd
 Antigo, WI 54409

thorswill@infralt.com
Phone 715-627-2710
Fax 715-627-2710

Ship To

Infrastructure Alternatives, Inc.
 Tommy Horswill
 Antigo WWTP
 N2420 Koszarek Rd
 Antigo, WI 54409

thorswill@infralt.com
Phone 715-627-2710
Fax 715-627-2710

Sales Rep

Fluid Technology Sales
 Travis Walker 920-219-1090
 t.walker@craneengineering.net

Senior Application Engineer
 Jesse Sage 920-257-0152
 j.sage@craneengineering.net

Crane Engineering is pleased to provide a quote for your review.

Terms	RFQ	Ship Via	FOB	Crane Order#
n15		Best Way	Warehouse	

Line	Qty	Product	Lead Time	Unit Price	Ext. Price
Rotating Assembly for Hidrostral F10K-MD Pump					
1	1		14 Weeks After Receipt of Order	\$31,988.00	\$31,988.00
		Rotating Assembly: Pump Size: F10K Pump Impeller: F10K-MD w/ Impeller Bolt Impeller Material: Ductile Iron Impeller Flange Material: Ductile Iron Motor: Immersible Motor, 50 HP, 1.05 SF, 1765 RPM, Standard Oil Cooling, 82 Feet Cable, FM, 460V Shaft Material: 420 Stainless Steel Sealing Type: Pump Side: Type M, Rubber Booted Single Spring Seal, SC/TC Motor Side: Type F, Rubber Bellows Single Spring Seal, SC/C Paint: Tnemec N69 Standard 2 Part Paint Also Includes Installation in Existing Casing			
2	1	OPTION: High Chrome Suction Liner (Optional)		\$3,809.00	\$3,809.00

Total \$31,988.00



**INFRASTRUCTURE
ALTERNATIVES, INC.**

To: The City of Antigo Public Works Committee

One of the older raw sewage pumps at the wastewater treatment plant has stopped operating. It stopped operating during a time of increased flow and there were some flooding issues at the plant. The pump has been rebuilt several times since its installation in 1996 and its life expectancy has been reached.

I have reached out to a few companies for replacement quotes and have received two, from Sabel Mechanical and Crane Engineering. The quotes include the installation of a new Hidrostral pump of the existing model series which eliminates the need to additional changes to the pump housing or piping. Both quotes are the same cost of \$31,988.00.

There is currently \$39,000.00 budgeted in the 2018 CIP plan for the pump's replacement. I ask that the committee please waive the bidding process of the city's purchasing policy and accept the two quotes I have collected. I suggest that the committee approves the replacement with Sabel Mechanical's bid of \$31,988.00, not to exceed \$39,000.00.

If you have any questions please do not hesitate to contact me.

Thank you,

Tommy Horswill | Project Manager

INFRASTRUCTURE ALTERNATIVES
N2420 Koszarek Road. | Antigo, WI 54409
715-627-2710 | Fax 715-627-2710 | Cell 715-216-6243
thorswill@iaewater.com | www.iaewater.com

Attachment: IAI Sewage Pump Memo (2175 : Sewage Pump Replacement)

QUOTE

DATE 6/5/2018**QUOTE #: 6134****SEND TO**

Antigo WWTP



W3150 County Road H, Fond du Lac, WI 549
920-904-5579

doug@sabelmechanical.com

Date	Job	Payment Term	QUOTE EXPIRES
6/5/2018	Influent pump replacement	30 DAYS	Today

QTY	DESCRIPTION	UNIT PRICE	LINE TOTAL
1	Rotating assembly, IS, F10K-MD ductile iron impeller, Mat1, immersible motor, 82 ft. cord. Labor and equipment for the install Electrical hook up Freight Due to the fluctuating material pricing and availability, quote is valid thru end of today's business day, Pricing may have to be adjusted at time of purchase and will be reflected when project is invoiced		

PAST DUE AMOUNTS ARE SUBJECT TO A FINANCE CHARGE AT THE MAXIMUM RATE ALLOWED BY STATE. REASONABLE COLLECTION FEES AND ATTORNEY FEES WILL BE ASSESSED TO ALL ACCOUNTS PLACED FOR COLLECTION

SUBTOTAL	\$ 31,988.00
SALES TAX	\$ NIC
TOTAL	\$ 31,988.00

Attachment: Sabel Mechanical Influent Pump Quote (2175 : Sewage Pump Replacement)